



NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. IN NEW CONSTRUCTION, ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
3. ON REROOFING PROJECTS, AN ACCEPTABLE ASPHALT BARRIER MUST BE INSTALLED OVER THE EXISTING FLASHING TO FULLY DIVORCE THE JM PVC FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
4. IF THE BACK EDGE OF THE SEAM PLATE IS GREATER THAN 2" (50 mm) FROM THE VERTICAL SUBSTRATE, THE WALL FLASHING MUST BE ADHERED UTILIZING JM PVC MEMBRANE ADHESIVE. IN ADDITION, IT IS NECESSARY TO ADHERE THE DECK SHEET WHEN THE BACK EDGE OF THE IN SEAM PLATE IS BETWEEN 2" (50 mm) AND 8" (200 mm) FROM THE VERTICAL SUBSTRATE. PLATE PLACEMENT GREATER THAN 8" (200 mm) IS UNACCEPTABLE.

DRAWING NO. PB-26	BASE TIE-IN (FASTENER AND PLATE)			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD PV26MEF	