


NOTES:

1. DETAILS TO BE USED IN CONJUNCTION WITH GUIDE SPECIFICATIONS CONTAINING REQUIREMENTS FOR NAILERS, INSULATION, ETC.
2. JM TPO EDGE SEALANT IS USED TO SEAL THE MEMBRANE EDGES WHERE REINFORCING FABRIC IS CUT AND EXPOSED. EDGE SEALANT IS REQUIRED ON ALL END LAPS, T-JOINTS AND FIELD CUT EDGES.
3. IN NEW CONSTRUCTION ACCEPTABLE SUBSTRATES INCLUDE EXTERIOR GRADE PLYWOOD, POURED OR PRECAST CONCRETE, CEMENT BLOCK OR MASONRY WALLS. CONTACT JM TECHNICAL SERVICES FOR OTHER SUBSTRATES.
4. ON REROOFING PROJECTS AN ACCEPTABLE ASPHALT BARRIER SHOULD BE INSTALLED OVER THE EXISTING FLASHING TO FULLY DIVORCE THE JM TPO FLASHING MEMBRANE FROM ANY INCOMPATIBLE MATERIALS.
5. IF THE BACK EDGE OF THE SEAM PLATE IS GREATER THAN 2" (50 mm) FROM THE VERTICAL SUBSTRATE, THE WALL FLASHING MUST BE ADHERED UTILIZING JM TPO BONDING ADHESIVE. IN ADDITION IT IS NECESSARY TO ADHERE THE DECK SHEET WHEN THE BACK EDGE OF THE IN SEAM PLATE IS BETWEEN 2" (50 mm) AND 8" (200 mm) FROM THE VERTICAL SUBSTRATE. PLATE PLACEMENT GREATER THAN 8" (200 mm) IS UNACCEPTABLE.
6. INSULATION MUST BE COMPATIBLE WITH JM TPO BONDING ADHESIVE.

DRAWING NO. TB-26	BASE TIE-IN (FASTENER AND PLATE)			 Johns Manville
	SCALE N.T.S.	ISSUE DATE 3-06	CAD TPO-3.11	